

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1157:117 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Digital Monitoring Products, 2500 N. Partnership Blvd, Springfield, MO 65803
Contact: Terry Shelton (417) 831-9362 FAX (417) 831-1325

DESIGN: Model iCOMsl Internet Alarm Communicator. Unit allows fire alarm control units to communicate as a primary signaling path over an Ethernet or Internet connection. Unit is intended to be installed in a Model XR20 or XR40 control unit as a subassembly for combination household fire and burglary alarm systems. Unit is compatible with any listed power limited fire alarm control unit which is listed for central station or receiving station via contact closure. For commercial fire applications unit requires the use of Model 377 trouble annunciator module installed in separate listed metal enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations and listee's installation instructions for details.

RATING: 12 or 24 VCD

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an internet alarm communicator for use with separately listed combination household fire and burglary alarm control units, Models XR20 and XR40 (CSFM Listing No. 7167-1157:103) and commercial fire applications when installed in a listed metal enclosure and used with listed Model 377 trouble annunciator module (CSFM Listing No. 7165-1157:104). Refer to listee's Installation Instruction Manual for details.

Burglary and other non-fire functions were not examined.

02-21-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**